

Chief Fire Officer: R Wilsher



Email: FireSafetyNorth.Fire@hertscc.gov.uk
Internet: www.hertsdirect.org

Fire & Rescue Service

The Licensing Officer
Stevenage Borough Council
Daneshill House
Danestrete
Stevenage
Herts SG1 1HN

North District Fire Safety
Longfield, Hitchin Road,
Stevenage Herts., SG1 4AE

Telephone : 01438 847352
Textphone : 01438 847353
Fax : 01438 847368
Direct Line : 01438 847352
Contact : District Manager
Our Ref : MC/pd/FS23/36164
Date : 07 April 2006

ENV. HEALTH

12 APR 2006

RECEIVED

FOR ADMIN

21 APR 2006

RECEIVED

Dear Sir/Madam,

THE LICENSING ACT 2003

*Pulse & Vogue Night Club (Liquid & Envy) Unit 6 Stevenage Leisure Park
Kings Park Six Hills Way Stevenage SG1 2UA*

Application for:- Variation of Premises Licence
Date of application:- 28th March 2006

Hertfordshire Fire and Rescue Authority, being the responsible Authority under the above Act, wish to make Representations in respect of this Application.

The particulars of the Representations, which are made in consideration of public safety and in accordance with the above Regulations, are specified in the attached Schedule.

Should you require any further clarification, please contact the above address quoting reference number **23/36164**.

Yours faithfully

District Manager, Fire Safety Enforcement



INVESTOR IN PEOPLE



Schedule of Representations for:-

***Pulse & Vogue Night Club (Liquid & Envy) Unit 6 Stevenage Leisure Park
Kings Park Six Hills Way Stevenage SG1 2UA***

***Date of application:- 28th March 2006
Application for:- Variation of Premises Licence***

- (1) Inadequate means of escape
- (2) Inadequate means of detection and giving warning in case of fire
- (3) Insufficient emergency lighting
- (4) Insufficient fire fighting equipment
- (5) Insufficient fire signage
- (6) Failure to adequately maintain necessary equipment
- (7) Failure to carry out a fire risk assessment
- (8) Failure to supply plans as required, to enable a determination to be made
- (9) Failure to supply plans in the prescribed format, to enable a determination to be made

Building Regulations

The variation involves structural alteration and will require Building Regulation Approval from a Building Control Body.