

Appendix 3(b)

**Additions to operating
schedule following
advice from Herts. Fire
and Rescue**

Internet: www.hertsdirect.org

Chief Fire Officer: R Wilsher OBE



The Licensing Officer
Stevenage Borough Council
Daneshill House
Danestrete
Stevenage
Herts
SG1 1HN

Hertfordshire Fire & Rescue
North District Fire Protection
Longfield, Hitchin Road
Stevenage SG1 4AE
Telephone : 01438 847352
Fax : 01438 847368
Text Phone : 01438 847353
Direct Line : 01438 847364
Contact : Mr T Copping
My Ref : TC/mc/23/36526
Your Ref :
Date : 21 October 2009

PADS FM SERVICE

26 OCT 2009

5 11 11 11

Dear Sir/ Madam

The Licensing Act 2003

The Regulatory Reform (Fire Safety) Order 2005

J's Bar and Lounge, Unit 6, The Plaza, Town Square, Stevenage, Herts SG1 1WS

Application for:

Premises License

Date of Application:

25th September 2009

On 19th October 2009 a meeting was held at the property named above with Mr Jeremy Dickens (owner) Vicky Alga (Environmental Health Officer) Jeff Mason (Licensing Officer) and myself. The following items were discussed and agreed by Mr Dickens to be carried out prior to the premises opening to the public.

1. The fire alarm system is to be serviced by a competent fire alarm engineer to the standard of BS 5839 or equivalent. The sound system for the premises is to be linked to the fire alarm system so that music will be automatically cut off, should the fire alarm activate.
2. The emergency lighting system is to be serviced by a competent emergency lighting engineer to the standard of BS 5266 or equivalent.
3. Signs and notices shall be provided to the standard of BS 5499 or equivalent.
4. Fire fighting equipment shall be provided to the standard of BS 5306 or equivalent.
5. Any wall linings used e.g. sound proofing, wallpaper, etc will be of class 0, surface spread of flame construction as defined in the current building regulations.



INVESTOR IN PEOPLE



6. All furniture and fittings will be to the standard of BS 5867 or equivalent.
7. All fire resisting doorsets leading onto the emergency exit corridors to the rear of the property shall conform fully with BS 8214 or equivalent.

Providing the above items are acted upon to the appropriate standard and the responsible person ensures compliance with the Regulatory Reform (fire safety) Order 2005 Hertfordshire Fire and Rescue Service do not object to this application and have no further representations to make.

A separate exterior smoking area outside the single door front emergency exit was discussed. This scheme will have to be submitted for Building Regulation approval, whereby the fire authority will be consulted. Our comments will be reserved until such a time as this consultation occurs.

Should you require any further clarification, please contact the officer named on the number above.

Yours faithfully



Terry Copping
Fire Protection
Inspecting Officer